

Protecting, Maintaining and Improving the Health of All Minnesotans

PUBLIC NOTICE

Important Information About Your Drinking Water

Tests show levels of Total Trihalomethanes above drinking water standards

Stewart public water system routinely monitors for the presence of drinking water contaminants. Previous testing results show that the average level of Total Triahalomethans (TTHMs) was above the standard, or maximum contaminant level (MCL) of 80 micrograms per liter (μ g/L). An MCL violation was issued for this system on April 11, 2025. Recent testing results show that the average level of TTHM was 114.1 μ g/L.

TTHMs are formed when naturally occurring organic matter combines with disinfectants added to kill microorganisms. They are by-products of drinking water disinfection. Some people who drink water containing TTHMs in excess of the MCL over many years may have an increased risk of getting cancer.

This is not an emergency. You do not need an alternative source of water, such as bottled water. However, if you have specific health concerns, consult your doctor. The use of carbon filters is not recommended for removal of TTHMs, as they may accumulate in the filter over time.

Your public water system is considering methods to reduce the levels of TTHMs, which may include an alternative water source or water treatment. You will be informed when the public water supply has reduced the levels and meets the standards.

Please share this information with all other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, hospitals, schools, prisons, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

The City has a plan in for approval at MDH. The problem will be taken care of by June 1st. This notice is being sent to you by Stewart

PWSID 1430009

Phone or mailing ac	ddress:	320-562-2518	cityofstewart@gmail.com	
Distribution Date:	4/16/2025			